

CERTIFICATE OF COMPLIANCE

Certificate Number 20171110-EX2855
Report Reference EX2855-19990917
Issue Date 2017-NOVEMBER-10

Issued to: GRISWOLD INDUSTRIES, DBA CLA-VAL CO
1701 PLACENTIA AVE,
COSTA MESA CA 92627-4416

**This is to certify that
representative samples of**

FIRE PUMP RELIEF VALVES
USL- Model: 750B-4KG1
The Model 750B-4KG1 fire pump relief valves 3 and 4 NPS are designed to mount between standard ANSI Class 150 or 300 pipe flanges as a wafer type valve.
The Model 750B-4KG1 fire pump relief valves 6, 8, and 10 NPS are constructed with separable "slip-on" style Class 150 or 300 raised face flanges.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL1478, Fire Pump Relief Valves
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

